

APPENDIX-XI

BUILDING SAFETY CERTIFICATE


No.- 56/Camp/2023-24

Date: 19/05/2023

Certified that the existing building SEVEN HILLS at Behind Guru Nanak Cold Storage, Pakka Bagh Etawah comprised of 0 (Zero) basement(s) and 3 (Three) upper floors owned/occupied by SEVEN HILLS, Behind Guru Nanak Cold Storage, Pakka Bagh, Etawah have complied with the building safety requirements in accordance with National Building code 2005, 2016 Rules, and verified by the officers concerned of UP PWD Etawah on 17/05/2023 in the presence of Mr. SAURABH DUBEY PRINCIPAL Seven Hills Inter College, Etawah Residence at 145 Jai Prakash Nagar Near Mahrea Mandir Etawah UP 206001 and that the building/premises is fit for occupancy up to classes XII with effect from 19/05/2023 for a period of 03 Years in accordance with rule.

1. Minimum height of first floor height 3.6m
2. two stair case premises provided with 200mm tread and 150mm riser.
3. Fire safety certificate separately issued by Fire department.
4. Teacher shall provided fire safety programme ^{in each} ^{class} ^{room}

Issued on 19/05/2023 at UPPWD Etawah by


17/05/23
सहायक अभियन्ता
निर्माण खण्ड-1
लोक निर्माण विभाग-इटावा

Gaurav Jain
Assistant Engineer
Nirmaan Khand 1
Uttar Pradesh Public Works Department
Police Lines Etawah

(Assistant Engineer & above office of concerned Govt. Department only)

Note: This certificate should be signed/issued by Assistant Engineer & above Office of concerned Govt. Department only

*The filled up certificate should be either in Hindi or English. If it is issued in vernacular language, translated notarized version in English be uploaded along with the original vernacular certificate as a single pdf.