

APPENDIX -XIII

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No.

Dated:

It is certified that an inspection team headed by .....SHIVAM KUMAR VERMA.....

(Name of Officers with designation) from .....SHIVAM KUMAR VERMA (D.M.).....

(Name of Department/ Office) inspected the .....U.P.J.N. RURAL ETAWAH.....

(Name & Address of the school) on ...10-05-2023...(date of inspection) and found that the

Seven Hills Inter College, Etawah.....( Name of school) has safe drinking water facilities

for the students and members of staff of the institution and is maintaining the hygienic sanitation

condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

The above is valid for a period of ...SIX MONTH..

Signature with Seal: .....

Name : ...SHIVAM KUMAR VERMA.....

Designation : ...D.M.....

Name & Address of the Office / Department : U.P.J.N RURAL  
ETAWAH

To

.....

.....

(Name & Address of the Institution)

\* The filled up certificate should be either in Hindi or English. If it is issued in vernacular language, translated notarized version in English be uploaded along with the original vernacular certificate as a single pdf.

# District Level Water Analysis Laboratories of Uttar Pradesh Jal Nigam (Rural) Etawah.

Issue No. : 01  
Issue Date: 10-05-2023  
Revision No.:  
Revision Date:

## Test Report Water

### Water Analysis Report

Report No.	1	Date	10.05.2023	Page No.	1
<b>Customer Details</b>					
Office Name & Address	Seven Hills Inter Collage Pakka Bagh Etawah				
Ref. Letter No. & Date	S.H./E.T.W./2023-24/11 06.05.2023				
<b>Basic Details of Sample</b>					
District	Etawah	Block		Village	
Gram Panchayat		Location	Seven Hills Inter Collage		
Habitation		Sample No		Date of S.C	06.05.2023
Water Source	Submersible	S. Collector	Saurabh Dubey		
Quantity of Sample	1	Analysis Completion Date	08.05.2023		
Receiving Date	06.05.2023				
Sample Depositor	Saurabh Dubey				
Analysis Start Date	06.05.2023				
<b>Environmental Condition</b>					
Temperature	30 °C	Humidity	33%		

S. No.	Analyzed Parameters	Observed Value	Specified Values as per BIS 10500:2012		Ref. Method of Analysis
			Acceptable Limit	Permissible	
1	Taste	Agreeable	Agreeable/Not Agreeable	Agreeable/Not Agreeable	IS 3025 (Part 8): 1984
2	Odour	Agreeable	Agreeable/Not Agreeable	Agreeable/Not Agreeable	IS3025(Part 5): 2018
3	Colour	05	5	15	IS 3025 (Part 4): 1983(Platinum Cobalt Visual Comparison Method)
4	Turbidity (NTU)	0.96	1	5	IS3025(Part-10) :1984 (Nephelometric method)
5	PH	7.06	6.5	8.5	IS3025(Part11) :1983 (Electrometric Method)
6	TDS (Mg/L)	198	500	2000	IS3025 (Part 16) :1984 Gravimetric Method
7	Alkalinity (Mg/L)	320	200	600	IS3025(Part-23) :1986 (indicator Method)
8	Total Hardness (Mg/L)	240	200	600	IS3025(Part-21) :2009 (EDTA)
9	Calcium	100	0.0	1	IS 3025(Part 26) 1986
10	Magnesium	140	NA	NA	IS 3025(Part 14) 2013
11	Sulphate (Mg/L)	120	200	400	IS3025(Part-24) :1986
12	Nitrate (Mg/L)	10	45	No Relaxation	IS3025)Part 34) 1988
13	Fluoride (Mg/L)	0.8	1.0	No Relaxation	IS3025(Part-60) 2008
14	Iron (Mg/L)	None	1.0	No Relaxation	IS 3025 (Part-53) : 2003(1,10 Phenanthroline Method)
15	Chloride (Mg/L)	60	250	1000	IS3025)Part-32) 1988
16	Total Coliform	Agreeable	100	No Relaxation	

- Note
- 1 This Certificate refers only to the particular sample (s) submitted for testing.
  - 2 This Certificate shall not be reproduced, except in full, unless written permission for the publication of an approved abstract has been obtained from Head of Laboratory
  - 3-The test result reported in this certificate are valid at the time of and under the stated conditions of measurements.
  - 4-Sample will be stored up to 7 days (in case of non perishable items only) from the date of issue of test reports unless otherwise specified.
  - 5-Parameters above permissible limit are written in Bold.
- Report Prepared By



Laboratory Contact Details Email-[etawahlab@gmail.com](mailto:etawahlab@gmail.com)